

DEPARTMENT OF TRANSPORTATION
DIVISION OF ENGINEERING SERVICES
OFFICE ENGINEER, MS 43
1727 30TH STREET
P.O. BOX 168041
SACRAMENTO, CA 95816-8041
FAX (916) 227-6214
TTY (916) 227-8454



*Flex your power!
Be energy efficient!*

**** WARNING ** WARNING ** WARNING ** WARNING ****
This document is intended for informational purposes only.

Users are cautioned that California Department of Transportation (Department) does not assume any liability or responsibility based on these electronic files or for any defective or incomplete copying, excerpting, scanning, faxing or downloading of the contract documents. As always, for the official paper versions of the bidders packages and non-bidder packages, including addenda write to the California Department of Transportation, Plans and Bid Documents, Room 0200, P.O. Box 942874, Sacramento, CA 94272-0001, telephone (916) 654-4490 or fax (916) 654-7028. Office hours are 7:30 a.m. to 4:15 p.m. When ordering bidder or non-bidder packages it is important that you include a telephone number and fax number, P.O. Box and street address so that you can receive addenda.

January 6, 2006

04-SM-1-63.8/64.6
04-1123K4
ER-1187(010)E

Addendum No. 5

Dear Contractor:

This addendum is being issued to the contract for construction on State highway in SAN MATEO COUNTY NEAR PACIFICA ON ROUTE 1 FROM 2.1 KM TO 1.3 KM SOUTH OF LINDA MAR BOULEVARD.

Submit bids for this work with the understanding and full consideration of this addendum. The revisions declared in this addendum are an essential part of the contract.

Bids for this work will be opened on February 7, 2006, instead of January 18, 2006.

This addendum is being issued to set a new bid opening date as shown herein and revise the Notice to Contractors and Special Provisions.

In the Special Provisions, Section 10-1.50, "PILING," under subsection "GENERAL", the following is added after the fifth paragraph:

"At the Contractor's option, CIDH piles at Piers 2 and 3 may be drilled and placed prior to completion of excavation to the bottom of footing elevations, as provided in the sixth paragraph, of Section 19-3.04 "Water Control and Foundation Treatment" of the Standard Specifications. Should the Contractor elect to drill prior to completion of the excavation to the bottom of the footing, the following additional requirements apply:

1. The Contractor shall submit a plan detailing the procedures of drilling and placing the CIDH pile prior to the completion of excavation to the bottom of footing elevation, as specified elsewhere in these specifications. Contractor's plans shall include:

- A. Methods and equipment for accurately determining and verifying the center of hole at pile cutoff elevation and placement of CIDH pile at centerline of hole at pile cut-off elevation.
- B. Methods and equipment for accurately determining and verifying pile reinforcement alignment and elevation at cutoff elevation.
- C. Method of protecting reinforcement and vertical inspection pipes after pile placement.

2. Axis of the hole at pile cutoff elevation shall not deviate from planned pile location as shown on the plans.

04-SM-1-63.8/64.6
04-1123K4

3. Additional cost due to or associated with the Contractor's choice to drill prior to completion of the excavation to the bottom of the footing, including, but not limited to, supporting structures, additional appurtenances, additional material, hard drilling, ground water, and other conditions brought about by the choice to drill prior to completion of excavation, shall be at the Contractor's expense."

To Proposal and Contract book holders:

Inquiries or questions in regard to this addendum must be communicated as a bidder inquiry and must be made as noted in the NOTICE TO CONTRACTORS section of the Notice to Contractors and Special Provisions.

Indicate receipt of this addendum by filling in the number of this addendum in the space provided on the signature page of the proposal.

Submit bids in the Proposal and Contract book you now possess. Holders who have already mailed their book will be contacted to arrange for the return of their book.

Inform subcontractors and suppliers as necessary.

This office is sending this addendum by confirmed facsimile to all book holders to ensure that each receives it. A copy of this addendum is available for the contractor's use on the Internet Site:

http://www.dot.ca.gov/hq/esc/oe/weekly_ads/addendum_page.html

If you are not a Proposal and Contract book holder, but request a book to bid on this project, you must comply with the requirements of this letter before submitting your bid.

Sincerely,

ORIGINAL SIGNED BY

REBECCA D. HARNAGEL, Chief
Office of Plans, Specifications & Estimates
Office Engineer