

DEPARTMENT OF TRANSPORTATION

DIVISION OF ENGINEERING SERVICES

OFFICE ENGINEER

1727 30th Street MS-43

P.O. BOX 168041

SACRAMENTO, CA 95816-8041

FAX (916) 227-6214

www.dot.ca.gov/hq/esc/oe

*Serious Drought.
Help save water!*

September 1, 2016

06-Ker-99-49.6
06-OH6424
Project ID 0614000266
ACNHP-P099(603)E

Addendum No. 3

Dear Contractor:

This addendum is being issued to the contract for CONSTRUCTION ON STATE HIGHWAY IN KERN COUNTY IN MCFARLAND AT KERN AVENUE PEDESTRIAN OVERCROSSING to revise the project plan and the *Notice to Bidders and Special Provisions*.

Submit bids for this work with the understanding and full consideration of this addendum. The revisions declared in this addendum are an essential part of the contract.

Bids for this work will be opened on Wednesday, September 7, 2016.

Project plan sheet 104 is replaced and attached for substitution for the like-numbered sheet.

In the Special Provisions, Section 59-3.03, the following paragraph is added after the first paragraph:

"For chain link railing posts, railing assembly and tubular handrailing on Kern Ave. POC (Bridge No. 50-0518), the 1st finish coat must match color no. 37038 of FED-STD-595. The 2nd finish coat must match color no. 27038 of FED-STD-595."

In the Special Provisions, Section 83-1.02I, the following paragraph is added after the first paragraph:

"Painting chain link railing posts, railing assembly and tubular handrailing must comply with section 59-3."

To *Bid* book holders:

Inquiries or questions in regard to this addendum must be communicated as a bidder inquiry and must be made as noted in the *Notice to Bidders* section of the *Notice to Bidders and Special Provisions*.

Submit the *Bid* book as described in the *Electronic Bidding Guide* at the Bidders' Exchange website.

http://www.dot.ca.gov/hq/esc/oe/electronic_bidding/electronic_bidding.html

Addendum No. 3
Page 2
September 1, 2016

06-Ker-99-49.6
06-0H6424
Project ID 0614000266
ACNHP-P099(603)E

Inform subcontractors and suppliers as necessary.

This addendum, EBS file and attachments are available for the Contractors' download on the Web site:

http://www.dot.ca.gov/hq/esc/oe/project_ads_addenda/06/06-0H6424

If you are not a *Bid* book holder, but request a book to bid on this project, you must comply with the requirements of this letter before submitting your bid.

Sincerely,



SHARRI BENDER EHLERT
District Director
District 6 Central Region

Attachment